

1 PIPES

1.1 MATERIALS

The proposed pipes are made of AISI 316 L 2B steel and meet the requirements of EN 1856-1 standard.


1.2 FEATURES

Table 1.1 Flue gas exhaust and combustion air inlet pipes

Code	Figure	D	L	Clamp (1)	Gasket (2)	Flue gas analysis socket
OTBO008	1.1 p. 1	80	500	yes	yes	no
OTBO009		80	1000	yes	yes	no
OTBO003		110	500	no	yes	no
OTBO001		110	1000	no	yes	no
OTBO004		130	500	no	yes	no
OTBO002		130	1000	no	yes	no
OTBO020	1.2 p. 1	80	1000	yes	no	yes
OTBO005		110	1000	no	no	yes
OTBO006		130	1000	no	no	yes


- 1 Figure 7.1 p. 9.
- 2 Double lip silicone seal, maximum temperature 230 °C, operating temperature 200 °C.

Figure 1.1 Pipe



A Pipe clamp (standard for pipes Ø 80 mm)

Figure 1.2 Pipe with flue gas analysis socket



A Pipe clamp (standard for pipes Ø 80 mm)


1.3 ADAPTERS

Table 1.2 Adapters

Code	Figure	D	d	Gasket (1)
ODTT003	1.3 p. 1	110	80	yes
ODTT004		130	80	yes

- 1 Double lip silicone seal, maximum temperature 230 °C, operating temperature 200 °C.

Figure 1.3 Adapter for exhaust/air pipes



2 ELBOWS

Table 2.1 Flue gas exhaust and combustion air inlet elbows

Code	Figure	D	Type	Clamp (1)	Gasket (2)
OCRV006	2.1 p. 2	80	45°	yes	yes
OCRV003	2.2 p. 2	110	45°	yes	yes
OCRV004	2.3 p. 2	130	45°	yes	yes
OCRV007	2.4 p. 2	80	90°	yes	yes
OCRV001	2.5 p. 2	110	90°	yes	yes
OCRV002	2.6 p. 2	130	90°	yes	yes
OCRV013	2.7 p. 2	80	45°	no	

1 Figure 7.1 p. 9.
 2 Double lip silicone seal, maximum temperature 230 °C, operating temperature 200 °C.

Figure 2.1 OCRV006




Figure 2.2 OCRV003




Figure 2.3 OCRV004




Figure 2.4 OCRV007




Figure 2.5 OCRV001




Figure 2.6 OCRV002





Figure 2.7 OCRV013



3 SPLIT PIPE KIT

Figure 3.1 OSCR006 split pipe flue gas exhaust




Figure 3.2 OSCR004 split pipe flue gas exhaust




Table 3.1 OSCR006 flue gas exhaust composition

	Code	D	L	Quantity	Figure
A	RTBO116	80	1000	2	1.2 p. 1
B	RRSN000	-	-	1	-
C	RTRM029	-	-	1	6.3 p. 8
D	NFSC010	80	-	2	7.1 p. 9

Table 3.2 OSCR004 flue gas exhaust composition

	Code	D	L	Quantity	Figure
A	RTBO790	130	1000	1	-
B	NFSC001	130	-	2	7.1 p. 9
C	RRSN003	130	-	2	-
D	KTRM008	130	-	1	-
E	RTBO790	110	1000	1	-
F	NFSC000	110	-	2	7.1 p. 9
G	RRSN002	110	-	2	-
H	KTRM009	110	-	1	-

4 COAXIAL FLUE GAS EXHAUSTS

For the identification of coaxial ducts, the first number refers to the connection diameter of the individual ducts, while the second refers to the diameter of the coaxial duct.

For example Ø 80/125 refers to a coaxial duct with connection diameters of the individual air/exhaust ducts 80 mm and coaxial duct diameter 125 mm.

Table 4.1 Coaxial flue gas exhausts (models in production)

	Wall coaxial		Roof coaxial			
	OSCR007 Ø 80/125 mm	OKTC004 Ø 130/180 mm	OSCR008 Ø 80/125 mm	OSCR009 Ø 100/150 mm	OKTC001 Ø 130/210 mm	OSCR002 Ø 130/210 mm
Next-R15	•	•	•	•	•	-
Next-R20	•	•	•	•	•	-
Next-R30	•	•	•	•	•	-
Next-R40	•	•	•	•	•	-
Next-R50	•	•	•	•	•	-
Next-R60	-	•	-	•	•	-
Next-R80	-	•	-	•	•	-
Next-G 20 EC	•	•	•	•	•	-
Next-G 30	•	•	•	•	•	-
Next-G 35 EC	•	•	•	•	•	-
Next-G 45	•	•	•	•	•	-
Next-G 60	•	•	•	•	•	-
Next-G 75 EC	•	•	•	•	•	-
Next-G 90	•	•	•	•	•	-
M20	-	-	-	-	-	•
M25	-	-	-	-	-	•
M30	-	-	-	-	-	•
M35	-	-	-	-	-	•
M40	-	-	-	-	-	•
M50	-	-	-	-	-	•
M60	-	-	-	-	-	•

• Applicable
- Not applicable

Table 4.2 Coaxial flue gas exhausts (models out of production)

	Wall coaxial		Roof coaxial		
	OSCR012 Ø 80/125 mm	OSCR011 Ø 130/180 mm	OSCR008 Ø 80/125 mm	OSCR009 Ø 100/150 mm	OKTC001 Ø 130/210 mm
G30
G45
G60	.	.	-	.	.
G100	.	.	-	.	.
K32
K45
K60	-	.	-	.	.
K100	-	.	-	-	.

• Applicable
- Not applicable

4.1 WALL

4.1.1 OSCR012

Figure 4.1 OSCR012 wall coaxial flue gas exhaust




Figure 4.3 RTBO559




Figure 4.4 RTBO124




Table 4.3 OSCR012 flue gas exhaust composition

	Code	D	L	Quantity	Figure
A	RTBO122	125	780	1	4.2 p. 4
B	RTBO559 (1)	80	275	1	4.3 p. 4
C	RTBO124 (1)	80	195	1	4.4 p. 4
D	NFSC010	80	-	2	7.1 p. 9

1 Complete with double lip silicone seal, maximum temperature 230 °C, operating temperature 200 °C.

4.1.2 OSCR011

Figure 4.5 OSCR011




Figure 4.2 RTBO122




Table 4.4 OSCR011 flue gas exhaust composition

	Code	D	L	Quantity	Figure
A	KOPT034	180	1000	1	4.6 p. 5
B	RDTT008	130/80	-	2	1.3 p. 1
C	RTBO160 (1)	80	185	1	4.7 p. 5
D	RCRV027	80	-	1	2.7 p. 2
E	RCRV015	80	-	1	2.1 p. 2
F	NFSC010	80	-	2	7.1 p. 9

1 Complete with double lip silicone seal, maximum temperature 230 °C, operating temperature 200 °C.

Figure 4.6 KOPT034





Figure 4.7 RTBO160



4.1.3 OSCR007

Figure 4.8 OSCR007




Table 4.5 OSCR007 flue gas exhaust composition

	Code	D	L	Quantity	Figure
A	RTBO122	125	780	1	4.2 p. 4
B	RTBO124 (1)	80	195	2	4.4 p. 4
D	NFSC010	80	-	2	7.1 p. 9

1 Complete with double lip silicone seal, maximum temperature 230 °C, operating temperature 200 °C.

4.1.4 OKTC004

Figure 4.9 OKTC004





Table 4.6 OKTC004 flue gas exhaust composition

	Code	D	L	Quantity	Figure
A	KOPT034	180	1000	1	4.6 p. 5
B	RDTT008	130/80	-	2	1.3 p. 1
C	RTBO117 (1)	80	250	1	4.10 p. 5
D	RCRV027	80	-	1	2.7 p. 2
E	RCRV015	80	-	1	2.1 p. 2
F	NFSC010	80	-	2	7.1 p. 9

1 Complete with double lip silicone seal, maximum temperature 230 °C, operating temperature 200 °C.

Figure 4.10 RTBO117




The OKTC004 wall coaxial flue gas exhaust can only be installed using the OSTF009 support bracket, available as optional.



If the OKTC004 wall coaxial flue gas exhaust is used for the installation of R15, R20 and G 20 EC gas unit heaters, there must be at least 800 mm between the rear panel of the gas unit heater and the wall (Figure 4.11 p. 6).

Consequently, it is not possible to secure the gas unit heater to the wall by means of the revolving wall support bracket OSTF020, if the coaxial wall flue gas exhaust OKTC004 is to be positioned on the same wall.

Figure 4.11 Minimum distance for installation with Next-R15/R20 and Next-G 20 EC



4.2 ROOF

4.2.1 OSCR008

Figure 4.12 OSCR008





Table 4.7 OSCR008 flue gas exhaust composition

	Code	D	L	Quantity	Figure
A	RTBO123	125	1280	1	4.13 p. 6

Figure 4.13 RTBO123



4.2.2 OSCR009

Figure 4.14 OSCR009




Table 4.8 OSCR009 flue gas exhaust composition

	Code	D	L	Quantity	Figure
A	RTBO129	150	1360	1	4.15 p. 6
B	RDTT004 (1)	100/80	150	2	4.16 p. 6

1 Complete with double lip silicone seal, maximum temperature 230 °C, operating temperature 200 °C.

Figure 4.15 RTBO129





Figure 4.16 RDTT004



4.2.3 OKTC001

Figure 4.17 OKTC001





Table 4.9 OKTC001 flue gas exhaust composition

Code	D	L	Quantity	Figure	
A	KOPT033	210	1850	1	4.18 p. 7

Figure 4.18 KOPT033



4.2.4 OSCR002

Figure 4.19 OSCR002




Table 4.10 OSCR002 flue gas exhaust composition

Code	D	L	Quantity	Figure	
A	KOPT033	210	1850	1	4.18 p. 7
B	RDTT003 (1)	110/130	125	1	4.21 p. 7
C	RDTT002 (1)	130/134	125	1	4.20 p. 7

1 Complete with double lip silicone seal, maximum temperature 230 °C, operating temperature 200 °C.

Figure 4.20 RDTT002





Figure 4.21 RDTT003



5 T CONNECTORS

Figure 5.1 T connector




Table 5.1 T connectors

Code	Figure	D	A	Clamp (1)	Gasket (2)
ORCC002	5.1 p. 8	80	170	yes	yes
ORCC000		110	135	yes	yes
ORCC001		130	135	yes	yes

- 1 Figure 7.1 p. 9.
 2 Double lip silicone seal, maximum temperature 230 °C, operating temperature 200 °C.

5.1 CAPS FOR T CONNECTORS

Figure 5.2 Cap for T connector




Table 5.2 Caps for T connectors

Code	Figure	D	d	A	B	Clamp (1)
OTPP002 (2)	5.2 p. 8	80	3/4"	52	16	yes
OTPP000		110	3/4"	57	24	yes
OTPP001		130	20	54	14	yes

- 1 Figure 7.1 p. 9.
 2 Complete with double lip silicone seal, maximum temperature 230 °C, operating temperature 200 °C.

6 TERMINALS


6.1 ROOF

Table 6.1 Roof terminals

Code	Figure	A	B	C	D	E	F
OTRM004 (1)	6.1 p. 8	200	185	130	80	95	55
OTRM000		300	210	165	110	80	45
OTRM001		300	185	140	130	80	45

- 1 Complete with clamp, refer to Figure 7.1 p. 9.

Figure 6.1 Roof terminal



6.2 WALL

Table 6.2 Wall terminal

Code	Figure	D	d	A	B
O12141320	6.2 p. 8	109	79	69	80
O12141330		141	109	69	80
O12141340		162	129	69	80

Figure 6.2 Wall terminal





Figure 6.3 OTRM005 double die-cast wall mounted terminal



- A Combustion air inlet
 B Flue gas exhaust
 The terminal protrudes from the wall 22 mm.



The die-cast terminal is not applicable to the M series.

7 PIPE CLAMPS

Figure 7.1 Pipe clamp




Table 7.1 Pipe clamps

Code	Figure	D
OFSC000	7.1 p. 9	110
OFSC001		130
OFSC010		80

8 PIPE ADAPTERS

The adapters allow the connection between M and M C series gas unit heaters and commercially available pipes.

Table 8.1 Pipe adapters

Code	Figure	D	d
OTBO011 (1)	8.1 p. 9	111	110
OTBO012 (1)		131	130

1. Complete with external o-ring (gas unit heater side) and internal double lip silicone seal, maximum temperature 230 °C, operating temperature 200 °C.

Figure 8.1 Pipe adapter

