

1 SCHEDULED ROUTINE MAINTENANCE

Perform the operations in the following Table 1.1 p. 1 on an annual basis.

Table 1.1 Scheduled routine maintenance

		Next-G	Next-R	M
Ordinary scheduled maintenance				
Check of the unit	clean the burner	√	√	√
	clean the ignition and flame sensor electrodes	√	√	√
	clean the fan	√	√	√
	clean the blower/exhaust fan	√	√	√
	check the % value of CO ₂	√	√	√
	check the unit safety devices	√	√	√
	check that the condensate discharge is clean	√	-	-